



lumini Solucoes em Iluminacao LTDA
www.lumini.com.br
Email:laboratorio@lumini.com.br
Tel:+55 11 3437-5555 Fax:+55 11 3437-5555
Address:Rua Ferreira Viana, 716 - Socorro - São Paulo/SP

lumini

LumCAT:

Luminaire: mini frame concentra 50 serie 3 e fc

LampCAT: modulo led 36W 30K irc 90

Ballast type: led driver 700mA

Report No:

Voltage(V): 127.5900

Test No:

Current(A): 0.3020

Number of Lamps: 1

Power (W): 38.3020

Lamp flux(lm): 4072.0

PF: 0.9940

Length(mm): 468

Width(mm): 17

Phm Type: C

Height(mm): 0

Photometric Results

Lumens(lm): 2842.28, Efficiency(%): 69.80% , Luminous Efficacy(lm/W): 74.21

Central intensity(cd): 16528.750, Maximum intensity(cd): 16528.750

Angle of maximum intensity: $C=0.0$ $\gamma=0.0$



Beam angle of C0 plane : 20.70

Aveage BeamAngle(IEC 61341):20.70


Equipment: equipamento lumini
Temperature(°C): 25.5

Date: 08/05/2025
Humidity(%): 60.0%


Operator: 01
Distance(m): 6.90



C0(Max): —————
C0/C180: —————
C90/C270: —————



Max , Ave Beam angle of C0 plane 20.70



(10%Imax) 1652.88	—
(20%Imax) 3305.75	—
(30%Imax) 4958.63	—
(40%Imax) 6611.5	—
(50%Imax) 8264.38	—
(60%Imax) 9917.25	—
(70%Imax) 11570.1	—
(80%Imax) 13223	—
(90%Imax) 14875.9	—

lumini

Luminance Limiting Curve(no luminous side)

Luminance Table


γ	45	50	55	60	65	70	75	80	85
C0	5315	3911	3075	2739	2894	3346	4217	6078	11810
C45	5315	3911	3075	2739	2894	3346	4217	6078	11810
C90	5315	3911	3075	2739	2894	3346	4217	6078	11810

L(Hor)(65)	L(Ver)(65)	L45(65)	L(Hor)(75)	L(Ver)(75)	L45(75)	L(Hor)(85)	L(Ver)(85)	L45(85)
2894	2894	2894	4217	4217	4217	11810	11810	11810

Glare Table

Glare	Quality	Service Values Illuminance(lx)							
1.15	A	2000	1000	500	<=300				
1.5	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.2	D				2000	1000	500	<=300	
2.55	E					2000	1000	500	<=300
		a	b	c	d	e	f	g	h

Luminance Limiting Curve



Illumination assessment according UGR											
Rf of Ceiling	70	70	50	50	30	70	70	50	50	30	
Rf of Wall	50	30	50	30	30	50	30	50	30	30	
Rf of Floor	20	20	20	20	20	20	20	20	20	20	
Room dimensions		Viewed crosswise					Viewed endwise				
X	Y										
2H	2H	9.21	10.10	9.61	10.46	10.82	8.82	9.71	9.22	10.06	10.43
	3H	9.83	10.63	10.26	11.01	11.40	9.46	10.26	9.89	10.64	11.03
	4H	10.41	11.15	10.85	11.55	11.96	10.04	10.78	10.48	11.17	11.59
	6H	11.35	12.02	11.81	12.44	12.89	10.98	11.65	11.44	12.07	12.52
	8H	11.97	12.61	12.43	13.04	13.49	11.61	12.25	12.07	12.68	13.13
	12H	12.77	13.38	13.24	13.82	14.28	12.44	13.05	12.90	13.48	13.94
4H	2H	9.21	9.94	9.65	10.34	10.75	8.85	9.59	9.29	9.98	10.40
	3H	10.09	10.71	10.56	11.15	11.61	9.77	10.39	10.23	10.82	11.29
	4H	10.97	11.50	11.44	11.96	12.46	10.65	11.18	11.12	11.64	12.14
	6H	12.18	12.65	12.69	13.14	13.64	11.86	12.33	12.37	12.82	13.32
	8H	13.01	13.45	13.53	13.94	14.46	12.70	13.14	13.22	13.63	14.15
	12H	14.04	14.45	14.57	14.93	15.50	13.75	14.15	14.28	14.64	15.21
8H	4H	11.27	11.70	11.79	12.20	12.72	10.99	11.43	11.52	11.93	12.45
	6H	12.80	13.15	13.34	13.67	14.22	12.53	12.89	13.07	13.40	13.96
	8H	13.90	14.19	14.46	14.75	15.29	13.64	13.93	14.20	14.49	15.03
	12H	15.19	15.41	15.77	15.97	16.53	14.95	15.17	15.53	15.72	16.29
12H	4H	11.37	11.77	11.89	12.26	12.82	11.11	11.51	11.63	12.00	12.57
	6H	13.06	13.35	13.62	13.91	14.45	12.81	13.11	13.38	13.67	14.21
	8H	14.23	14.46	14.81	15.01	15.58	14.00	14.22	14.58	14.78	15.34
Variation with the observer position at spacings:											
S = 1.0H	1.6/-1.1					1.6/-1.1					
S = 1.5H	1.8/-1.2					1.8/-1.2					
S = 2.0H	2.1/-1.2					2.1/-1.2					
Standard tables:	BKBF					BKBF					
Uncorrected UGR	-3.4					-3.4					

依据CIE Publ. 117 计算 UGR, S/H = 0.25